

LONGS PEAK WATER DISTRICT

DISTRICT SPECIFICATION DETAIL DRAWING

NOTE
LPWD TO SUPPLY METER.
ALL OTHER COMPONENTS
TO BE SUPPLIED BY
DEVELOPER/CONTRACTOR.
ALL COMPONENTS TO BE
INSTALLED BY DEVELOPER/
CONTRACTOR.

3/4" X 5/8" METER

SERVICE VALVE
(TYPICAL)

3/4" TESTABLE DOUBLE
CHECK ASSEMBLY
(FEBCO 850)

METER PIT

TOP VIEW

5'

GROUND LEVEL

CASTINGS INC. 16" TRAFFIC
RATED LID WITH 1 7/8"
DRILLED HOLE
MODEL # CI-70-16

FROST PROOF
LID

SERVICE VALVE

DOUBLE CHECK
BACKFLOW
PREVENTER

PROPERTY LINE

3/4" X 5/8"
METER

3/4" COPPER YOKE
FORD MODEL #
TVB92-30W-MM33-J
WITH SPECIAL 10 3/4"
SPACING FOR FEBCO
850 BACKFLOW
PREVENTER

DFW PLASTICS INC.
20" X 24" X 36"
HW WHITE
METER PIT

TRACER WIRE

BRASS SADDLE
AND CORP. STOP

CTS POLY SERVICE LINE
SEE DISTRICT FOR
CURRENT SPECIFICATION

3/4" MALE
I.P. THREAD

WATER MAIN

RESIDENTIAL METER PIT WITH BROWN WATER IRRIGATION