LONGS PEAK WATER DISTRICT DISTRICT SPECIFICATION DETAIL DRAWING BACKFILL FULL-BACKFILL W/ON-DEPTH WITH SITE MATERIALS IN NON-ROADWAY ROADBASE IN ດຄໍ ROADWAY AREAS. AREAS. 90% COMPACTION 95% COMPACTION REQUIRED. REQUIRED. SQUEEGEE BEDDING DEPTH AS REQUIRED BY ENGINEER (MINIMUM 6") 2" MINUS GRAVEL* SUBGRADE * EXTREME CONDITIONS MAY REQUIRE WASHED ROCK GRAVEL. 12" 12" PIPE O.D. + 24" SPECIAL TRENCH DETAIL SCALE: NONE REV. 1-1-06