

# LONGS PEAK WATER DISTRICT

## DISTRICT SPECIFICATION DETAIL DRAWING

NOTE  
LPWD TO SUPPLY METER.  
ALL OTHER COMPONENTS  
TO BE SUPPLIED BY  
DEVELOPER/CONTRACTOR.  
ALL COMPONENTS TO BE  
INSTALLED BY DEVELOPER/  
CONTRACTOR.

DUAL CHECK VALVE

SERVICE VALVE

3/4" X 5/8" METER

METER PIT

CASTINGS INC. 16" TRAFFIC  
RATED LID WITH 1 7/8"  
DRILLED HOLE  
MODEL # CI-70-16

TOP VIEW

5"

GROUND LEVEL

FROST PROOF  
LID

SERVICE VALVE

12"

DUAL  
CHECK  
VALVE

PROPERTY LINE

METER

3/4" COPPER YOKE  
FORD MODEL #  
VBHH92-30W-MM33-J

DFW PLASTICS INC.  
20" X 24" X 36"  
HW WHITE  
METER PIT

TRACER  
WIRE

30"

36"

BRASS SADDLE  
AND CORP. STOP

CTS POLY SERVICE LINE  
SEE DISTRICT FOR  
CURRENT SPECIFICATION

18"

3/4" MALE  
I.P. THREAD

WATER MAIN

### STANDARD RESIDENTIAL METER PIT